



TOWN AND COUNTRY PLANNING ACT 1990

DACORUM BOROUGH COUNCIL

Application Ref. No. 4/1573/90

Harry Dalby Engineering Ltd  
Gloucester Crescent  
Wigston,  
Leicester  
LE8 2YQ

DEVELOPMENT ADDRESS AND DESCRIPTION  
=====

Tring Service Station, Western Road, Tring,

SUB.OF DET.OF FILTRATION EXTRACTION EQUIPMENT PURSUANT OF P/P 4/0696/90 (S/S  
BLD.FOR CAR PAINT SPRAYING OVEN)

Your application for *the approval of details or reserved matters* dated and received on 06.11.1990 has been **GRANTED**, subject to any conditions set out on the attached sheet(s).

Director of Planning.

Date of Decision: 21.01.1991

(encs. - Conditions and Notes).



CONDITIONS APPLICABLE  
TO APPLICATION: 4/1573/90

Date of Decision: 21.01.1991

The top of the chimney stack to the paint spraying oven shall be at a minimum height of 0.5 m above the roof level of the oven building.

**REASON:**

In the interest of health and safety and for the avoidance of doubt.