

Town Planning 4/0300/76  
Ref. No. ....

## TOWN &amp; COUNTRY PLANNING ACTS, 1971 and 1972

Other 478/76D  
Ref. No. ....

THE DISTRICT COUNCIL OF ..... **DACORUM** .....

IN THE COUNTY OF HERTFORD .....

To Mr. R. Crabtree,  
2 Station Road,  
Tring,  
Herts.

Agent: Mr. R. I. Onslow,  
9 Huxley Close,  
Bicester,  
Oxon. OX6 8FX.

..... Single storey side extension .....

at 2 Station Road, Tring, Herts. ....

Brief  
description  
and location  
of proposed  
development.

In pursuance of their powers under the above-mentioned Acts and the Orders and Regulations for the time being in force thereunder, the Council hereby permit the development proposed by you in your application dated 15th March 1976 and received with sufficient particulars on 22nd March 1976 and shown on the plan(s) accompanying such application, subject to the following conditions:-

- (1) The development to which this permission relates shall be begun within a period of 5 years commencing on the date of this notice.
- (2) The materials used externally shall match those on the existing building of which this development shall form a part.
- (3) The garage hereby permitted shall be used for domestic purposes only, incidental to the enjoyment of the dwelling within the same curtilage and for no other purpose.

The reasons for the Council's decision to grant permission for the development subject to the above conditions are:—

- (1) To comply with the requirements of Section 41 of the Town & Country Planning Act, 1971.
- 2) To ensure the appearance of the development is satisfactory.
- 3) To maintain the residential character of the area.

Dated.....15th.....day of.....April.....1976.....

Signed.....

Director of Technical Services

Designation .....

NOTE

(1) If the applicant wishes to have an explanation of the reasons for this decision it will be given on request and a meeting arranged if necessary.

(2) If the applicant is aggrieved by the decision of the local planning authority to refuse permission or approval for the proposed development, or to grant permission or approval subject to conditions, he may appeal to the Secretary of State for the Environment, in accordance with section 36 of the Town and Country Planning Act 1971, within six months of receipt of this notice. Appeals must be made on a form which is obtainable from the Secretary of State for the Environment, Whitehall, London, S.W.1.) The Secretary of State has power to allow a longer period for the giving of a notice of appeal but he will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of appeal. The Secretary of State is not required to entertain an appeal if it appears to him that permission for the proposed development could not have been granted by the local planning authority, or could not have been so granted otherwise than subject to the conditions imposed by them, having regard to the statutory requirements, to the provisions of the development order, and to any directions given under the order.

(3) If permission to develop land is refused, or granted subject to conditions, whether by the local planning authority or by the Secretary of State and the owner of the land claims that the land has become incapable of reasonably beneficial use in its existing state and cannot be rendered capable of reasonably beneficial use by the carrying out of any development which has been or would be permitted, he may serve on the Common Council, or on the Council of the county borough, London borough or county district in which the land is situated, as the case may be, a purchase notice requiring that council to purchase his interest in the land in accordance with the provisions of Part IX of the Town and Country Planning Act 1971.

(4) In certain circumstances, a claim may be made against the local planning authority for compensation, where permission is refused or granted subject to conditions by the Secretary of State on appeal or on a reference of the application to him. The circumstances in which such compensation is payable are set out in section 169 of the Town and Country Planning Act 1971.

# DACORUM DISTRICT COUNCIL

A. H. Lewis B. Eng., C. Eng., M.I.C.E., F.I.Mun.E.  
Director of Technical Services

TOWN HALL  
HEMEL HEMPSTEAD  
HERTS. HP1 1UE

Telephone 3131

4th November, 19 76

To Mr. R. I. Onslow,  
7 Huxley Close, Bicester, Oxon.

## PUBLIC HEALTH ACTS 1936 and 1961

### CLEAN AIR ACT 1956

NOTICE IS HEREBY GIVEN that in pursuance of the above Acts and of the Building Regulations made under the Public Health Act 1961 (as amended) the **DACORUM DISTRICT COUNCIL** have REJECTED the plans deposited by you with the Council on the 30th day of September, 19 76 and numbered 478/76D showing a proposal to Erect a Single Storey Utility Room and Garage Extension at 2 Station Road, Tring, Herts.  
for Mr. and Mrs. R. Crabtree

because:

(1) the plans are defective in the following particulars

The drawings have not been prepared in a satisfactory manner and do not show sufficient details to ensure compliance with relevant Building Regulations as required by section 64 (1) Public Health Act 1936, Rules A & D Schedule 2 of the Building Regulations 1972 as applied by Regulation A.10.

(2) the proposed work would not conform to the following sections of the Public Health Act, 1936, ~~and~~  
~~on the Clean Air Act 1956~~  
**Section 55 - Means of access.**

(3) the proposed work would not conform to the following Building Regulations  
**Regulation D.3 - Structural stability of foundations.**

**Regulation D.8 - Stability of structure above foundations.**

**Regulation N.17 - Cesspools.**

  
Director of Technical Services

If you question this decision you may apply to the local magistrates court to determine the matter under Section 64(3) of the Public Health Act, 1936.

B.C. 20.

# DACORUM DISTRICT COUNCIL

A. H. Lewis B. Eng., C. Eng., M.I.C.E., F.I.Mun.E.  
Director of Technical Services

TOWN HALL  
HEMEL HEMPSTEAD  
HERTS. HP1 1UE

Telephone 3131

12 AUG 1976

19

To MR R I DOWSON

7 HUXLEY CLOSE, BICESTER,

OXON.

## PUBLIC HEALTH ACTS 1936 and 1961

### CLEAN AIR ACT 1956

NOTICE IS HEREBY GIVEN that in pursuance of the above Acts and of the Building Regulations made under the Public Health Act 1961 (as amended) the **DACORUM DISTRICT COUNCIL** have

REJECTED the plans deposited by you with the Council on the 22<sup>nd</sup> day of JUNE 1976.

and numbered 478/760 showing a proposal to ERECT A SINGLE STOREY UTILITY ROOM

AND GARAGE EXTENSION AT 2 STATION ROAD TRING

for MR R CRABTREE.

because:

- (1) the plans are defective in the following particulars

The drawings have not been prepared in a satisfactory manner and do not show sufficient details to ensure compliance with relevant Building Regulations as required by section 64 (1) Public Health Act 1936, Rules A & D. Schedule 2 of the Building Regulations 1972 as applied by Regulation A.10.

- (2) the proposed work would not conform to the following sections of the Public Health Act, 1936, and/or the Clean Air Act 1956.

- (3) the proposed work would not conform to the following Building Regulations

Regulation D.8 Stability of structure above foundations.  
N.15. Drains or private sewers passing through  
or under walls or under buildings.

Director of Technical Services

# DACORUM DISTRICT COUNCIL

A. H. Lewis B. Eng., C. Eng., M.I.C.E., F.I.Mun.E.  
Director of Technical Services

TOWN HALL  
HEMEL HEMPSTEAD  
HERTS. HP1 1UE

Telephone 3131

- 4 NOV 1976

19

To MR. R. J. OSLOW.

7 HUXLEY CLOSE.  
BICESTER. OXON.

## PUBLIC HEALTH ACTS 1936 and 1961

### CLEAN AIR ACT 1956

NOTICE IS HEREBY GIVEN that in pursuance of the above Acts and of the Building Regulations made under the Public Health Act 1961 (as amended) the **DACORUM DISTRICT COUNCIL** have

REJECTED the plans deposited by you with the Council on the 30<sup>th</sup> day of SEPTEMBER 1976.

and numbered 478/76D showing a proposal to ERECT A SINGLE STOREY UTILITY ROOM

A GARAGE EXTENSION at 2 STATION ROAD, TRING, HERTS.

for MR & MRS R. CRABTREE.

because:

(1) the plans are defective in the following particulars

The drawings have not been prepared in a satisfactory manner and do not show sufficient details to ensure compliance with relevant Building Regulations as required by section 64 (1) Public Health Act 1936, Rules A & D, Schedule 2 of the Building Regulations 1972 as applied by Regulation A.10.

(2) the proposed work would not conform to the following sections of the Public Health Act, 1936, and/or the Clean Air Act 1956:

Section 55 - Means of access

(3) the proposed work would not conform to the following Building Regulations

Regulation D3 Structural stability of foundation.  
D8 Stability of structure above foundation.  
A.17. Basements

Director of Technical Services

If you question this decision you may apply to the local magistrates court to determine the matter under Section 64(3) of the Public Health Act, 1936