

Town Planning
Ref. No. ... 4/CL87/76

TOWN & COUNTRY PLANNING ACTS, 1971 and 1972

Other
Ref. No. ... 410/76D

THE DISTRICT COUNCIL OF IN THE COUNTY OF HERTFORD

To

Mr. J. Smith,
17 Langford,
London Road,
Kingsgate,
Kt. St. Albans, Herts.

Agent: Mr. J. J. Perkin,
28 Raleigh Drive,
Whetstone, N.B.

... 1/11/76 ...
at ... 57 Langford, London Road, Kingsgate, Kt. St. Albans,
Herts.

Brief
description
and location
of proposed
development.

In pursuance of their powers under the above-mentioned Acts and the Orders and Regulations for the time being in force thereunder, the Council hereby permit the development proposed by you in your application dated 7th April 1976 and received with sufficient particulars on 9th April 1976 (see note 645 Pp 1976) and shown on the plan(s) accompanying such application, subject to the following conditions:-

- (1) The development to which this permission relates shall be begun within a period of 3 years commencing on the date of this notice.

The reasons for the Council's decision to grant permission for the development subject to the above conditions are:—

- (1) To comply with the requirements of Section 41 of the Town & Country Planning Act, 1971.

Dated..... 9th day of June 1976

Signed.....

Designation Director..of..Technical Services

NOTE

(1) If the applicant wishes to have an explanation of the reasons for this decision it will be given on request and a meeting arranged if necessary.

(2) If the applicant is aggrieved by the decision of the local planning authority to refuse permission or approval for the proposed development, or to grant permission or approval subject to conditions, he may appeal to the Secretary of State for the Environment, in accordance with section 36 of the Town and Country Planning Act 1971, within six months of receipt of this notice. Appeals must be made on a form which is obtainable from the Secretary of State for the Environment, Whitehall, London, S.W.1.) The Secretary of State has power to allow a longer period for the giving of a notice of appeal but he will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of appeal. The Secretary of State is not required to entertain an appeal if it appears to him that permission for the proposed development could not have been granted by the local planning authority, or could not have been so granted otherwise than subject to the conditions imposed by them, having regard to the statutory requirements, to the provisions of the development order, and to any directions given under the order.

(3) If permission to develop land is refused, or granted subject to conditions, whether by the local planning authority or by the Secretary of State and the owner of the land claims that the land has become incapable of reasonably beneficial use in its existing state and cannot be rendered capable of reasonably beneficial use by the carrying out of any development which has been or would be permitted, he may serve on the Common Council, or on the Council of the county borough, London borough or county district in which the land is situated, as the case may be, a purchase notice requiring that council to purchase his interest in the land in accordance with the provisions of Part IX of the Town and Country Planning Act 1971.

(4) In certain circumstances, a claim may be made against the local planning authority for compensation, where permission is refused or granted subject to conditions by the Secretary of State on appeal or on a reference of the application to him. The circumstances in which such compensation is payable are set out in section 169 of the Town and Country Planning Act 1971.

Detailed Points Requiring Attention to Plan 412/76D

1. The proposed w.c. connection is not acceptable, i.e., the connection at the foot of an existing S. & V.P. at low level below the floor level. The proposed P.V.C. drain under the floor slab is not considered acceptable.

It is suggested that a connection be made to the S. & V.P. a level above the floor slab with clearing access at this connection and the system independently ventilated. This arrangement should be provided with $\frac{1}{2}$ hour fire encasement. If it is not possible to obtain necessary falls a new inspection chamber will be required on the underground drain.

2. Specify inner skin blockwork type to meet the requirements of Regulation F.3.

T28/BEH
23/6/76