

TOWN AND COUNTRY PLANNING ACT 1990

DACORUM BOROUGH COUNCIL

Application Ref. No. 4/0564/94

Crest Homes (Eastern) Ltd
Crest House
Progression Centre
Mark Road
Hemel Hempstead
Herts

DEVELOPMENT ADDRESS AND DESCRIPTION
=====

Tunnel Fields, Sector J K L, Berkhamsted


SUBMISSION OF DETAILS OF VIBRATION PROTECTION FOR PLOTS 1-18 PURSUANT TO
CONDITION 12 OF PLANNING PERMISSION 4/1416/92 (86 DWELLINGS)

Your application for *the approval of details or reserved matters* dated 28.04.1994
and received on 28.04.1994 has been *GRANTED*, subject to any conditions set out
on the attached sheet(s).

Director of Planning.

Date of Decision: 01.06.1994

(encs. - Conditions and Notes).



CONDITIONS APPLICABLE
TO APPLICATION: 4/0564/94

Date of Decision: 01.06.1994

1. The dwellings on Plots 1-4 shall be constructed using the Rackham concrete beam system, or such other method as may be agreed in writing with the local planning authority prior to the commencement of construction of the dwellings, for the ground and first floor.

Reason: To minimise the probability of adverse comment in respect of vibration in accordance with BS6472:1992 (Guide to Evaluation of Human Exposure to Vibration In Buildings).