

TOWN AND COUNTRY PLANNING ACT 1990

DACORUM BOROUGH COUNCIL

Application Ref. No. 4/0585/94

Admiral Homes Ltd
Jansel House
Stopsley
Luton
LU2 7XJ

DEVELOPMENT ADDRESS AND DESCRIPTION
=====

Tunnel Fields Sector J K L, Berkhamsted, Herts


SUBMISSION OF DETAILS OF PROTECTION OF DWELLINGS FROM VIBRATION PURSUANT TO
CONDITION 12 OF PLANNING PERMISSION 4/1416/92 (86 DWELLINGS)

Your application for *the approval of details or reserved matters* dated 03.05.1994
and received on 03.05.1994 has been **GRANTED**, subject to any conditions set out
on the attached sheet(s).

Director of Planning.

Date of Decision: 30.08.1994

(encs. - Conditions and Notes).



CONDITIONS APPLICABLE
TO APPLICATION: 4/0585/94

Date of Decision: 30.08.1994

Conditions - None

NOTE: The reports submitted by Admiral Homes Ltd and prepared by Soil Mechanics Ltd, ref: PJLE/8679/12/1 (26 April 1994) and PJLE/8679/12/2 (8 August 1994), indicate that no additional measures are necessary to protect the dwellings from vibration and that vibration levels within dwellings will be within the "low probability of adverse comment" threshold specified in British Standard 6472 (1992) and adopted by the Council as the appropriate criteria for this site.