

DACORUM DISTRICT COUNCIL

A. H. Lewis B. Eng., C. Eng., M.I.C.E., F.I.Mun.E.
Director of Technical Services

TOWN HALL
HEMEL HEMPSTEAD
HERTS. HP1 1UE

Telephone 3131

26th June, 1975

To Mr. M.T.L. Laing,
115 London Road, Markyate, Herts.

PUBLIC HEALTH ACTS 1936 and 1961

CLEAN AIR ACT 1956

NOTICE IS HEREBY GIVEN that in pursuance of the above Acts and of the Building Regulations made under the Public Health Act 1961 (as amended) the **DACORUM DISTRICT COUNCIL** have

REJECTED the plans deposited by you with the Council on the 11th day of June, 1975 and numbered 632/75D showing a proposal to **Erect a single storey extension.**

at 115 London Road, Markyate, Herts.

for Mr. M.T.L. Laing

because:

(1) the plans are defective in the following particulars

The drawings have not been prepared in a satisfactory manner and do not show sufficient details to ensure compliance with relevant Building Regulations as required by section 64 (1) Public Health Act 1936, Rules A & D Schedule 2 of the Building Regulations 1972 as applied by Regulation A.10.

(2) the proposed work would not conform to the following sections of the Public Health Act, 1936, and/or the Clean Air Act 1956.

(3) the proposed work would not conform to the following Building Regulations

Regulation H.2 - Construction of private stairways.



Director of Technical Services