

DACORUM DISTRICT COUNCIL

A. H. Lewis B. Eng. C. Eng. M.I.C.E. F.I.Mun.E.
Director of Technical Services

TOWN HALL
HEMEL HEMPSTEAD
HERTS. HP1 1UE

Telephone 3131

15th July, 1976

To Mr. D. Lloyd, A.R.I.B.A., Dip.T.P.,
Ind Coope Ltd., P. O. Box 105,
194 High Street, Watford.

PUBLIC HEALTH ACTS 1936 and 1961

CLEAN AIR ACT 1956

NOTICE IS HEREBY GIVEN that in pursuance of the above Acts and of the Building Regulations made under the Public Health Act 1961 (as amended) the DACORUM DISTRICT COUNCIL have REJECTED the plans deposited by you with the Council on the 16th day of June, 1976 and numbered 997/76D showing a proposal to Erect a Single Storey Extension to Form Cask and Bottle Stores at The Crabtree Public House, Leverstock Green Road, Hemel Hempstead. for Allied Breweries (U.K.) Ltd., 107 Station Road, Burton-on-Trent.

because:

- (1) the plans are defective in the following particulars


The drawings have not been prepared in a satisfactory manner and do not show sufficient details to ensure compliance with relevant Building Regulations as required by section 64 (1) Public Health Act 1936, Rules A & D Schedule 2 of the Building Regulations 1972 as applied by Regulation A.10.

- (2) the proposed work would not conform to the following sections of the Public Health Act, 1936, and/or the Clean Air Act 1956.

- (3) the proposed work would not conform to the following Building Regulations

Regulation N.12 - Means of access to drains and private sewers.

Regulation P. 3 - Ventilation of sanitary accommodation.



Director of Technical Services