

Application Ref. No. 4/1408/90 LB

Lloyds Bank PLC 71 Lombard Street London EC3P 3BS



Robert Burns & Assoc. 2 Church Street Aylesbury Bucks HP20 2QS

DEVELOPMENT ADDRESS AND DESCRIPTION

205 High Street, Berkhamsted

RETENTION OF DEVELOPMENT WITHOUT COMPLIANCE WITH CONDITION 4 OF 4/0054/90LB

Your application for *listed building consent* dated 03.10.1990 and received on 04.10.1990 has been *GRANTED*, subject to any conditions set out on the attached sheet(s).

OrinBarnark

Director of Planning.

Date of Decision: 08.11.1990

(encs. - Conditions and Notes).

CONDITIONS APPLICABLE TO APPLICATION: 4/1408/90 LB

Date of Decision: 08.11.1990



- The works to which this consent relates shall be begun within a period of five years commencing on the date of this notice.
- 2. No work shall be started on the development hereby permitted until details of materials to be used externally shall have been submitted to and approved by the local planning authority, and the development hereby permitted shall be carried out in the materials so approved.
- All materials, slates, bricks and white painted timber windows shall match existing.
- 4. The blind boxes to the first floor rear windows shall be retained. The central window and blind box shall be relocated to the right hand side opening on the first floor rear elevation.
- 5. All brick arches over new windows shall be rubbed or rough gauged flat arches.
- Copings to proposed parapets to the existing and proposed single storey rear extensions shall be reconstituted stone to match a sample to be submitted to and approved by the local planning authority.
- 7. The existing single storey rear extension shall be clad with brick to match the new works and a parapet added as indicated on Drawing 8943/5A of Plan 4/0054/90LB.

REASONS:

- To comply with the provisions of s.56A of the Town and Country Planning Act 1971.
- To ensure a satisfactory appearance.
- 3-6 In the interests of preserving the character and appearance of the building.
- 7. To ensure a satisfactory appearance.