



PLANNING

Civic Centre Marlowes
Hemel Hempstead
Herts HP1 1HH

DEVEREUX
200 UPPER RICHMOND ROAD
LONDON
SW15 2SH

Applicant:

ST ALBANS & HEMEL HEMPSTEAD HOSPITAL TRUST
WAVERLEY ROAD
ST ALBANS
HERTS
AL3 5TL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION - 4/01497/97/FUL

HEMEL HEMPSTEAD GENERAL HOSPITAL, HILLFIELD ROAD, HEMEL
HEMPSTEAD, HERTS, HP2 4AD
REPLACEMENT OF EXISTING CHILLER UNITS TO INCLUDE NOISE
ATTENUATORS

Your application for full planning permission dated 10 September 1997 and received on 24 September 1997 has been **GRANTED**, subject to any conditions set out overleaf.

Director of Planning

Date of Decision: 06 November 1997

CONDITIONS APPLICABLE TO APPLICATION: 4/01497/97/FUL

Date of Decision: 06 November 1997

1. The development hereby permitted shall be begun before the expiration of five years from the date of this permission.

Reason: To comply with the requirements of Section 91 (1) of the Town and Country Planning Act 1990.

2. The level of noise emitted from the site shall not exceed 45 dB Laeq as measured on the boundaries of the site when measured over a 5 minute period.

Reason: In the interests of the amenity of adjoining residents.